

AN ORDINANCE AMENDING SECTION 11 OF ORDINANCE NO. 16 OF THE BOROUGH OF INDIAN LAKE KNOWN AS THE "ORDINANCE FOR THE GOVERNMENT AND OPERATION OF THE WATERWORKS OF THE BOROUGH OF INDIAN LAKE; PRESCRIBING RULES AND REGULATIONS APPLICABLE TO CERTAIN BOROUGH OFFICERS AND EMPLOYEES, TO CUSTOMERS OF THE SAID WATERWORKS AND TO THE GENERAL PUBLIC; AND PRESCRIBING PENALTIES FOR VIOLATION.


Section 11: Except in case of emergency, every main or distributing pipe, before acceptance by the Borough, shall be subject to a hammer test under a hydrostatic pressure of three hundred (300) pounds to the square inch.

AMENDED TO READ AS FOLLOWS:

Section 11: Except in cases of emergency every main or distributing pipes, before acceptance by the Water Authority shall be subject to a hammer test under hydrostatic pressure of a minimum 150 pounds per square inch or 50 pounds over pipe pressure at tap site. All pipe laid, copper, galvanized, brass or plastic must not have any soldered or leaded fittings. Below surface grade, use of sleeves, dressers, flared, or compression fittings only.


ORDAINED AND ENACTED into law by the Borough Council of the Borough of Indian Lake in lawful session assembled on the 11th day of February, 1977.

BOROUGH OF INDIAN LAKE




John E. Meehan, President
Indian Lake Borough Council

ATTEST:



Borough Secretary

Approved this 11th day of February, 1977.

BY 

Mayor

I hereby certify that the foregoing Ordinance is Ordinance No. 31 approved February 11, 1977, duly advertised and trascribed.



Secretary, Borough of Indian
Lake